

## Private Sewage System Minimum Distances

If there is not a main building between the disposal system and the water course the minimum distance between the effluent disposal component of the private sewage system and the water course is 90 meters.

### Septic tanks, sewage holding tanks or sewage effluent tanks shall not be located within:

- 10 meters (33 ft.) from any water source or water well;
- 10 meters (33 ft.) from any water course;
- 1 meter (3.25 ft.) from any property line, and
- 1 meter (3.25 ft.) from any building.

### A disposal field, measured from any part of a weeping lateral trench shall not be located within:

- 1.5 meters (5 ft.) from any property line;
- 100 meters (330 ft.) from a municipal licensed water well;
- 10 meters (33 ft.) from any basement or cellar;
- 15 meters (50 ft.) from any water source or water well;
- 15 meters (50 ft.) from any water course, except as provided in Article 2.1.2.4;
- 1 meter (3.25 ft.) from any non-basement building; and
- 5 meters (17 ft.) from a septic tank.

### A treatment mound shall not be located within:

- 3 meters from any property line;
- 100 meters (330 ft.) from a municipal licensed water well
- 15 meters from any water source or water well;
- 15 meters from any water course;
- 3 meters from a septic tank;
- 10 meters from any basement or cellar; and
- 10 meters from any (non-basement) building.

### An effluent discharge to the ground surface shall not be located within:

- 50 meters (165 ft.) from any water source or water well;
- 100 meters (330 ft.) from a municipal licensed water well;
- 45 meters (150 ft.) from any water course, except as required by article 2.1.2.4;
- 45 meters (150 ft.) from a building; and
- 90 meters (300 ft.) from any boundary property line.

An open discharge system shall not be installed on a property located within a quarter section where **more than 4** parcels, excluding the remnant of the parcel, have been subdivided out of the quarter section.